

XP95 ZONE MONITOR

FUNCTION

The XP95 Zone Monitor powers and controls the operation of a zone of up to 20 Series 60 Apollo fire detectors from a loop of XP95 addressable monitors and ancillary devices.

FEATURES

The Zone Monitor is factory preset to return a pseudo-analogue value of 16 when all detectors on the zone are in quiescent state and 64 when a detector changes to the alarm state. The Zone Monitor latches in the alarm state.

A 6.2k Ω end-of-line resistor is fitted to monitor cables for open- and short-circuit faults. Alternatively, an active end-of-line monitor may be used in conjunction with diode bases and a capacitor of up to 50 μ F fitted at the Zone Monitor wiring terminals.

In either case a pseudo-analogue value of 4 is transmitted during open- or short-circuit faults.

ELECTRICAL CONSIDERATIONS

The Zone Monitor is loop powered and operates at 17–28V DC with protocol pulses of 5–9V.

PROTOCOL COMPATIBILITY

The Zone Monitor operates only with control equipment using the Apollo Series 90, XP95 or Discovery protocol.



Part no 55000-813 (surface mount)

PROTOCOL BIT USAGE

The control equipment transmits a 10-bit message to the Zone Monitor:

The **output (or forward command) bits** from the control equipment have the following functions:

When **output bit 2** is set to logic 1 on two or more consecutive polling cycles, the current limit on the zone is increased to enable full illumination of the LED of the detector in the alarm state.



When **output bit 1** is set to logic 1 on two or more consecutive polling cycles, the remote test facility is initiated and a load equivalent to a fire alarm state is placed across the wiring to the conventional detectors.

When **output bit 0** is set to logic 1 on two or more consecutive polling cycles, voltage on the zone is switched to 0V to reset the detectors.

When **output bit 0** is set to logic 0 on two or more consecutive polling cycles, the zone voltage is restored.

The zone voltage low period should be at least 2 seconds.

The next **seven bits** transmitted correspond to the **address (as set on the DIL switch)** of the device to be polled.

A response message is then sent by the Zone Monitor to the control equipment:

The **interrupt bit** is always set to logic 0.

The seven **analogue value bits** are set to return a pseudo-analogue value of 16 in normal conditions. A value of 64 is sent if a detector changes to alarm state. If an open- or short-circuit fault occurs, or a reset is in progress, the Zone Monitor returns a pseudo-analogue value of 4.

The **input bits** confirm execution of the commands given in the output bits as follows:

Input bit 2 is set to logic 1 when the Zone Monitor has accepted a command to increase the current limit on the zone to fully illuminate a detector LED.

Input bit 1 is set to logic 1 when the Zone Monitor has accepted a command to apply a remote test.

Input bit 0 is set to logic 1 when the Zone Monitor has accepted a command to reset the zone (zone voltage low).

The **type bits** are used to identify the type of unit making the response. The type code of the Zone Monitor is set to 100 00 (bits 2, 1, 0, 4, 3 respectively). Bits 2, 1, 0 are sent immediately after the input bits, bits 4 and 3 are sent in the XP95 protocol extension.

The Zone Monitor sends **seven bits** of data to confirm its address and then **one bit (XP95 flag)** to confirm that the device can use the XP95 protocol.

The **alarm flag** is set if another device is in an alarm state and has not been polled for one second. (The Zone Monitor places an alarm flag if its

analogue value is 64 and the device has not been polled for one second. This flag is set on the data stream of another device, as described in the XP95 Protocol Guide, PP1036).

The next **two bits** returned by the device are bits 4 and 3 of the type code.

The next **five bits** are the second analogue block and are not used by the Zone Monitor.

The **parity bit** is set to logic 1 or logic 0 so that the Zone Monitor always responds with an even number of data bits.

The final **seven bits** are used to transmit the alarm address if the alarm flag is set.

NOTES ON USE

- 1. Zone voltage is regulated to $19 \pm 1V$ for any loop voltage greater than 22V. If the loop voltage falls below 22V, the zone voltage is approximately 1.5V below the loop voltage. It is important to ensure that under worst-case conditions, the zone voltage is above the minimum operating voltage for the conventional detectors.*
- 2. Alarm conditions are latched internally by the Zone Monitor. It is therefore necessary to reset the alarm even if non-latching conventional detectors are used.*
- 3. The Zone Monitor may be used to power and control intrinsically safe detectors via safety barriers with resistance values between 300 and 350 ohms. To use the Zone Monitor with intrinsically safe devices, cut the wire link near the LED.*
- 3. To comply with BS5839: Part 1 response time requirements, manual call points can only be incorporated into zones connected by the Zone Monitor to XP95 systems if the control panel is programmed to recognise the alarm flag.*
- 4. Manual call points can be located at any point in the zone wiring if active end-of-line monitoring with diode detector bases is used. If a 6.2 k Ω resistor is used for monitoring, manual call points must be connected between the Zone Monitor and the first detector (see Figure 2).*

MECHANICAL CONSTRUCTION

The Zone Monitor is normally supplied with a backbox for surface mounting, and is also available without the backbox for flush mounting. Both versions are for indoor use only.

A red LED, visible through the front cover of the enclosure, is lit when the zone is in an alarm state.

The backbox is a polycarbonate moulding.

Dimensions and weight of Zone Monitor (surface mount):

150mm x 90mm x 48mm 230g.

Technical Data

Series 90/XP95 line voltage	17V–28VDC
Zone voltage (Loop voltage \geq 22V)	19V \pm 1V
(Loop voltage $<$ 22V)	loop voltage $-1.5V$
Maximum current consumption at 24V (6.2k Ω EOL)	
switch-on surge, max 150ms	2.8mA
quiescent	4mA + detector load
alarm	11mA
(19mA when increased current enabled)	
short-circuit	11mA
End-of-line resistor value	6.2k Ω \pm 5% 1/3 W
Stabilisation time on power-up	4 seconds
Maximum capacitor on zone terminals	50 μ F
Operating temperature	-20° C to $+70^{\circ}$ C
Humidity (no condensation)	0% – 95%
Shock, Vibration and Impact	EFSG/F/95/007
IP rating	54
Radiated emissions	to BS EN 50081–1
Radiated immunity	to BS EN 50081–2



EMC DIRECTIVE 89/336/EEC

The XP95 Zone Monitor, Part No. 55000-813/814 complies with the essential requirements of the EMC directive 89/336/EEC, provided that it is used as described in this PIN sheet.

A copy of the Declaration of Conformity is available from Apollo on request.

Conformity of the XP95 Zone Monitor with the EMC directive does not confer compliance with the directive on any apparatus or systems connected to it.

Schematic diagram and wiring connections




Fig.1 Connection to loop




Fig.2 Zone connection - standard bases with 6.2 k Ω monitoring resistor at end-of-line




Fig.3 Zone connection - diode bases with active EOL device

Table of analogue values related to circuit status and zone load (input resistance)

Safe area circuit	Intrinsically safe circuit	Status	Analogue value
$<150\Omega$	$<450\Omega$	Short-circuit fault	4
150 Ω to 200 Ω	450 Ω to 500 Ω	Indeterminate	4 or 64
200 Ω to 2.6k Ω	500 Ω to 2.6k Ω	Alarm	64
2.6k Ω to 3.5k Ω	2.6k Ω to 3.5k Ω	Indeterminate	64 or 16
3.5k Ω to 6.8k Ω	3.5k Ω to 6.8k Ω	Normal	16
6.8k Ω to 7.5k Ω	6.8k Ω to 7.5k Ω	Indeterminate	4 or 16
$>7.5k\Omega$	$>7.5k\Omega$	Open-circuit fault	4